

Appendix 4

From: Neil Aston-Baugh <Neil.Aston-Baugh@wmfs.net>
Sent: 24 October 2023 08:25
To: Licensing Team for Alcohol & Gambling
<Licensing_Team@sandwell.gov.uk>
Cc: xxxxxxxxxxxx
Subject: Fire Authority representation to a premises licence

CAUTION: This email originated from outside of the Council / Children's Trust. Do not click links or open attachments unless you recognise the sender and know the content is safe

OFFICIAL

LICENSING ACT 2003

NAME OF PREMISES: Chulo Restaurant

ADDRESS: 5 Carters Green, West Bromwich B70 9QP

I refer to the application for the Grant of a Premises Licence made in respect of the above premises.

I have visited the premises and there are some fire safety issues which affect the Licensing Objective of Public Safety.

- The Fire Alarm system was not working.
- The Fire extinguisher tests were out of date
- there was no fire risk assessment.

Consequently, **The Fire Authority hereby makes representation to the application.**

The Fire Authority will not reconsider its representation until it has been provided with evidence that the following work has been suitably carried out:

- **The Fire alarm system must be repaired by a qualified fire alarm engineer and a copy of the test certificate in accordance with BS5839, should be sent to the Fire Authority.**
- **The Fire Extinguishers must be serviced and a copy of the certificate sent to the Fire Authority.**

Should you require any further information or clarification, please do not hesitate to contact me.

Regards

xxxxxxxxxx

Fire Safety Officer -LEEPS Team

xxxxxxxxxxxxxxxxxxxxxxxxxx

Telxxxxxxxxxx

Email : xxxxxxxxxxxxxxxxxxxxxx

Team Email: xxxxxxxxxxxxxxxx

Fire Safety Admin Email xxxxxxxxxxxxxxxx

Appendix 4



West Midlands Fire Service

Unless expressly stated otherwise, the information contained in this e-mail is confidential and is intended only for the named recipients. You must not copy, distribute, or take any action or reliance upon it. Any unauthorised disclosure of the information contained in this e-mail is strictly prohibited. If you have received it in error please notify us immediately on 0121 380 6067 or return it to <mailto:postmaster@wmfs.net> and then destroy it.

The information contained in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information is legally exempt from disclosure, the confidentiality of this e-mail and your reply cannot be guaranteed.

Any opinions expressed in this e-mail (including attachments) are those of the author and do not necessarily reflect the opinions of West Midlands Fire Service. Nothing in this e-mail message amounts to a contractual or other legal commitment on the part of West Midlands Fire Service unless confirmed by a communication signed on behalf of the Chief Fire Officer.

West Midlands Fire Service information is available from <http://www.wmfs.net>

This footnote also confirms that this e-mail message has been swept for the presence of computer viruses but does not guarantee that it is free from viruses and you should check all e-mail and attachments with your own anti-virus systems.

OFFICIAL