

From: xxxxxxxxxxxxxxxxxxxxxxxxx
Sent: 18 December 2023 15:36
To: xxxxxxxxxxxxxxxxxxxxxxxxx
Cc: xxxxxxxxxxxxxxxxxxxxxxxxx
Subject: Fire Authority representation to a premises licence application

CAUTION: This email originated from outside of the Council / Children's Trust. Do not click links or open attachments

OFFICIAL

Licensing Act 2003
NAME OF PREMISES: Mediterranean Grill
ADDRESS: 214 Causeway Green Road, Oldbury B68 8LS

I refer to the application for the Grant of a Premises licence made in respect of the above premises.

The Fire Authority hereby makes representation to the application on the grounds of Public Safety for the following reason.

It is the opinion of the Fire Authority that the plan/s submitted with the application fail/s to comply with The Licensing Act 2003 (Premises Licences and Club Premises Certificates) Order 2005- part 4 - Regulation 23- plans

In order to rectify this matter an amended plan/s detailing the full demise of the premises, the location and type of all fire safety equipment, including fire alarm, emergency lighting and fire exit signs , fire exits ,safety equipment in areas where cooking may take place, and the direction of exit doors on the means of escape should be forwarded to this Authority, other responsible Authorities and the Licensing Authority.

Please confirm also ;

- 60mins fire resistance is provided between occupancies, including the underside of the stairs leading to the first floor flat

A building regulations application should also be made to the extent that the layout differs significantly from any previously approved plans. Please also provide planning approval for the fire exits to open across council owned pathways, if this is the case.

Should you require any further information or clarification, please do not hesitate to contact me.

xxxxxxxxxxxxxxxxxxxxxxxx
Fire Safety Officer -LEEPS Team
Tipton Fire Station
Alexandra Road
Tipton
West Midlands
DY4 7NZ

xxxxxxxxxxxxxxxxxxxxxxxx
Email : xxxxxxxxxxxxxxxxxxxxxxxx
Team Email: xxxxxxxxxxxxxxxxxxxxxxxx
Fire Safety Admin Email firesafety.admin@wmfs.net



West Midlands Fire Service

Unless expressly stated otherwise, the information contained in this e-mail is confidential and is intended only for the named recipients. You must not copy, distribute, or take any action or reliance upon it. Any unauthorised disclosure of the information contained in this e-mail is strictly prohibited. If you have received it in error please notify us immediately on 0121 380 6067 or return it to <mailto:postmaster@wmfs.net> and then destroy it.

The information contained in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information is legally exempt from disclosure, the confidentiality of this e-mail and your reply cannot be guaranteed.

Any opinions expressed in this e-mail (including attachments) are those of the author and do not necessarily reflect the opinions of West Midlands Fire Service. Nothing in this e-mail message amounts to a contractual or other legal commitment on the part of West Midlands Fire Service unless confirmed by a communication signed on behalf of the Chief Fire Officer.

West Midlands Fire Service information is available from <http://www.wmfs.net>

This footnote also confirms that this e-mail message has been swept for the presence of computer viruses but does not guarantee that it is free from viruses and you should check all e-mail and attachments with your own anti-virus systems.